



X-702-ANOD DECLARATION OF CLASSIFICATION

We, Panidis S.A., declare that our product:

Code: X-702-ANOD.

Description: Spring assisted anodize level handle with 8mm square spindle for

opening doors.

Has passed the test of classification in accordance to

EN 1906:2012

With bellow coding system according to the Standart:

Category	Durability	Door	Fire	Safety	Corrosion	Security	Type of
of use		mass	resistance	o all o ty	resistance	2 2 2 2	operation
3	6	-	0	0	4	0	В

Issued date: 22/5/2014

The handle consists of: Inner base of high quality PA6 material, 8mm galvanized steel square spindle, galvanized zamak internal adaptor, high quality galvanized steel spring and anodize in 15-18µm handle and cup.

The classification as described above, drifts from tests in Panidis S.A. Test Laboratory executed, according to the cited standards.